Section 15. Plain Language Summary (Instructions Page 40)

This information is required for new, major amendment, and renewal applications. It is not required for minor amendment or minor modification applications.

If you are subject to the alternative language notice requirements in 30 Texas Administrative Code §39.426, you must provide a translated copy of the completed plain language summary in the appropriate alternative language as part of your application package. For your convenience, a Spanish template has been provided below.

ENGLISH TEMPLATE FOR TPDES or TLAP NEW/RENEWAL/AMENDMENT APPLICATIONS

DOMESTIC WASTEWATER

The following summary is provided for this pending water quality permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 Texas Administrative Code Chapter 39. The information provided in this summary may change during the technical review of the application and are not federal enforceable representations of the permit application. Vista View Mobile Homes, LLC (CN606055564) proposes to operate Vista View Mobile Home Community (RN111563854). a wastewater treatment facility using an aerobic process. The facility will be located on FM 1488 approximately 1,600 feet west of Bowler Road, in Hockley, Waller County, Texas 77447.

This application is for a new application to discharge effluent from a wastewater treatment facility designed for treating 48,000 GPD

Discharges from the facility are expected to contain biochemical oxygen demand (BOD), total suspended solids (TSS), ammonia nitrogen (NH,-N), and Escherichia coli. Additional potential pollutants are included in the Domestic Technical Report 1.21, Section 3. Domestic Wastewater will be treated by the Bio-Clear BC-50-ES with an operating capacity of 50,000 GPD. The wastewater from this unit will be treated using an aerobic process. The process for the wastewater from this development will be flowing with begin with the influent, then travel though the bar screen, then the equalization basin, aeration tank, clarifier, then finally the effluent that will be pumped to the discharge point approximately 1,600 feet to a tributary of Three Mile Creek. The sludge will be removed once a week using a VAC truck and be disposed at a permitted facility.

RECEIVED

SEP 19 2022

Water Quality Applications Team